



Department of Safety and Professional Services
Division of Industry Services
Plumbing Product Review
4822 Madison Yards Way
P.O. Box 7162
Madison, Wisconsin 53707-7162
Phone 608-266-2112
Web <http://dsps.wi.gov>
Email dsps@wisconsin.gov
TTY: Contact Through Relay

Governor Tony Evers Dawn Crim, Secretary

May 31, 2022

Dept. of Safety and Professional Services
Bureau of Technical Services
Division of Industry Services
Brad Johnson - Section Chief
4822 Madison Yards Way
Madison WI 53705

Re: Description: POWTS Component Manual
Manufacturer: Dept. of Safety and Professional Services
Product Name: Mound Component Manual for POWTS (Version 2.1), (May 2022-2027)
Model Number(s): v. 2.1
eSLA PTO No.: PP-051700078-PTOVPCR

The specifications and/or plans for this plumbing product have been reviewed and determined to comply with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2027.

This approval is contingent upon compliance with the following stipulation(s):

1. A copy of this approval letter shall be submitted with all plans using the Mound Component Manual for POWTS (Version 2.1), (May 2022-2027).

Plans submitted without a copy of this approval letter may be denied.
2. This approval recognizes that POWTS systems designed, installed and maintained in accordance with this manual will provide treatment and dispersal of domestic wastewater that is acceptable in the context of ch. 383 Wis. Adm. Code.
3. Systems installed in accordance with this POWTS Component Manual shall use wastewater tanks approved by the department. If a given tank is approved and meets the published specifications contained in the manual, then redundant approval of the tank is not required. The installation shall not compromise the structural integrity of the tank.
4. Systems installed in accordance with this POWTS Component Manual shall be installed, maintained and used in strict accordance with the manufacturer's published instructions, Chapters 381-387 Wis. Adm. Code and this product approval. If there is a conflict between the manufacturer's instructions and the Wis. Adm. Code or this Plumbing Product Approval, then the Wis. Adm. Code and this Plumbing Product Approval shall take precedence.
5. Complete operation and maintenance instructions POWTS systems designed in accordance with this manual shall be provided to each system owner and remain onsite.
6. Systems designed in accordance with this manual shall be installed by persons holding the proper license or registration in accordance with Wis. Stats. § 145.
7. Drain, waste and vent piping used to install these systems shall conform to s. SPS 384.30 (1), (2) and (3) Wis. Adm. Code.

8. Cleanouts shall be installed in drain piping associated with the installation of these systems in accordance with s. SPS 382.35 Wis. Adm. Code.
9. Commercial food processing, food production, food service, restaurants, taverns and similar establishments which may generate greases, fats, oils or similar substances; shall have state-approved grease interceptors installed upstream of POWTS systems designed in accordance with this manual in accordance with s. SPS 382.34 Wis. Adm. Code.
10. DSPS POWTS plan approval shall be obtained from the department's Private Sewage Section, or the appropriate agent county, for:
 - a. each installation of POWTS systems designed in accordance with this manual; and
 - b. high-strength and/or commercial POWTS systems designed in accordance with this manual.
11. A sanitary permit shall be obtained, in accordance with s. SPS 383.21 Wis. Adm. Code, from the county, or other local authority having jurisdiction, for each proposed installation of systems designed in accordance with this manual.
12. A complete and acceptable soil evaluation report, conforming to s. SPS 385.40 Wis. Adm. Code, shall be performed for all proposed systems designed in accordance with this manual.

Technical notations:

- a. This approval supersedes the approval issued May 9, 2017 under product file no. 20170148.

The department is in no way endorsing this product or any advertising and is not responsible for any situation which may result from its use.

Sincerely,

Brad Johnson – Section Chief
Department of Safety and Professional Services
Bureau of Technical Services
Division of Industry Services
Phone: 920 492-5605
Email: Bradley.Johnson@Wisconsin.gov

MOUND COMPONENT MANUAL
FOR PRIVATE ONSITE
WASTEWATER TREATMENT SYSTEMS
(VERSION 2.1)
May 2022
Exp. end of May 2027

State of Wisconsin
Department of Safety & Professional Services
Division of Industry Services



**MOUND COMPONENT MANUAL
FOR PRIVATE ONSITE WASTEWATER TREATMENT SYSTEMS**

TABLE OF CONTENTS	Page
I. Introduction and Specifications	3
II. Definitions	6
III. Description and Principle of Operation	7
IV. Soil and Site Requirements	8
V. Fill and Cover Material	9
VI. Design	9
VII. Site Preparation and Construction	18
VIII. Operation, Maintenance and Performance Monitoring	20
IX. References	22
X. Mound Worksheet	23
XI. Example Worksheet	30
XII. Plan Submittal and Installation Inspection	36

**Republished in May 2022 by Department of Safety & Professional Services
Division of Industry Services Publication SBD-10691**

ADA Statement

The Department of Safety and Professional Service is an equal opportunity service provider and employer. If you need assistance to access services or need material in an alternate format, please contact the Department at (608) 266-2112 or TTY Contact Through Relay.

I. INTRODUCTION AND SPECIFICATIONS

This Private Onsite Wastewater Treatment System (POWTS) component manual provides design, construction, inspection, operation, and maintenance specifications for a mound component. However, these items must accompany a properly prepared and reviewed plan acceptable to the governing unit to help provide a system that can be installed and function properly. Violations of this manual constitute a violation of chs. SPS 383 and 84, Wis. Adm. Code. The mound component must receive influent flows and loads less than or equal to those specified in Table 1. When designed, installed, and maintained in accordance with this manual, the mound component provides treatment and dispersal of domestic wastewater in conformance with ch. SPS 383 of the Wis. Adm. Code. Final effluent characteristics will comply with s. SPS 383.41, Wis. Adm. Code when inputs are within the range specified in Tables 1 to 3. Design variations to this manual will constitute an “Individual Site Design” which require exclusive plan review conducted by state staff.

Note: Detailed plans and specifications must be developed and submitted for review and approved by the governing unit having authority over the plan for the installation. Also, a Sanitary Permit must be obtained from the department or governmental unit having jurisdiction. See Section XII. for more details.

Table 1 INFLUENT FLOWS AND LOADS	
Design Wastewater flow (DWF)	≤ 5000 gal/day
Monthly average value of Fats, Oil and Grease (FOG)	≤ 30 mg/L
Monthly average value of five day Biochemical Oxygen Demand (BOD)	≤ 220 mg/L
Monthly average value of Total Suspended Solids (TSS)	≤ 150 mg/L
Design loading rate of fill	≤ 1.0 gal/ft ² /day if BOD ₅ or TSS > 30 mg/L or ≤ 2.0 gal/ft ² /day if BOD ₅ and TSS ≤ 30 mg/L
Design loading rate of the basal area	= soil application rate of effluent with maximum monthly average values of BOD and TSS of ≤ 30 mg/L when distribution component receives effluent with a BOD ₅ and TSS of ≤ 30 mg/L or when fill material depth is ≥ 12 inches as measured at the D dimension.
Volume of a single dose to absorption component	≥ 5 times void volume of the distribution lateral (s) and ≤ 20% of the design wastewater flow
Design wastewater flow (DWF) from one and two-family dwellings	Based on s. SPS 383.43 (3), (4), or (5), Wis. Adm. Code

Table 1 INFLUENT FLOWS AND LOADS (continued)	
Design wastewater flow (DWF) from public facilities	≥ 150% of estimated daily wastewater flow in accordance with Table 4 of this manual or s. SPS 383.43 (6), Wis. Adm. Code
Linear loading rate for systems with in-situ soils having a soil application rate of ≤ 0.3 gal/ft ² /day within 12 inches of fill material	≤ 4.5gal/ft/day
Wastewater particle size	≤ 1/8 inch
Distribution cell area per orifice	≤ 12 ft ²

Table 2 SIZE AND ORIENTATION	
Distribution cell width (A) ^a	≤ 10 feet
Total distribution cell area (A x B) ^a	≥ Design wastewater flow rate ÷ design loading rate of the fill material
Orientation	Longest dimension parallel to surface grade contours on sloping sites.
Deflection of distribution cell on concave slopes	≤ 10%
Fill material depth at up slope edge of distribution cell (D) ^a	1. ≥ 6 inches when fill is placed on in situ soil listed in Table 383.44-3, Wis. Adm. Code, having fecal coliform treatment capabilities of ≤ 36 inches, or 2. ≥ 12 inches, but not greater than 36 inches when fill is placed on in situ soil listed in Table 383.44-3, Wis. Adm. Code, having fecal coliform treatment capabilities of > 36 inches.
Distribution cell depth (F) ^a	≥ 8 inches + nominal size of distribution pipe
Depth of cover material at top center of distribution cell area (H) ^a	≥ 12 inches
Depth of cover material at top outer edge of distribution cell area (G) ^a	≥ 6 inches
Basal area	≥ Design wastewater flow rate + Design loading rate of basal area as specified in Table 1

Note a: Letter corresponds to letters referenced in figures, formulas and on worksheets.

Table 3 OTHER SPECIFICATIONS	
Bottom of distribution cell	Level
Slope of original grade	≤ 25% in area of basal area of the mound
Depth of in situ soil to high groundwater elevation and bedrock under basal area	≥ 6 inches
Vertical separation between distribution cell infiltrative surface and seasonal saturation defined by redoximorphic features, groundwater, or bedrock	≥ Equal to depth required by s. SPS 383 Table 383.44-3, Wis. Adm. Code
Horizontal separation between distribution cells	≥ 3 ft.
Fill material	Meets ASTM Specification C-33 for fine aggregate
Size for basal area (for level sites) (B x W) ^a	Cell length x [Total mound width]
Size for basal area (for sloping sites) (B x {A +I}) ^a	Cell length x [(# of cells x cell width) ÷ (# of cells – 1) x cell spacing] + down slope width]
Effluent application	By use of pressure distribution network conforming to sizing methods of either Small Scale Waste Management Project publication 9.6, entitled “Design of Pressure Distribution Networks for Septic Tank—Soil Absorption Systems” or Dept. of Safety & Professional Services publication SBD-10706, entitled “Pressure Distribution Component Manual for Private Onsite Wastewater Treatment Systems”
Piping Material	Meets requirements of s. SPS 384.30 (2), Wis. Adm. Code for its intended use
Distribution cell stone aggregate material	Meets requirements of s. SPS 384.30 (6) (i), Wis, Adm. Code
Fabric cover over distribution cell when stone aggregate is used	Geotextile fabric meeting s. SPS 384.30 (6) (g), Wis. Adm. Code
Number of observation pipes per distribution cell	≥ 2
Location of observation pipes for level components Location of observation pipes for components on a slope	Observation pipes will be installed in each distribution cell so as to be representative of a cell’s hydraulic performance. <ul style="list-style-type: none"> • be located such that there are a minimum of two • installed in each dispersal cell at opposite ends from one another • be located near the dispersal cell ends • be at least 6 inches from the end wall and sidewall • be installed at an elevation to view the horizontal or level infiltrative surface within the dispersal cell. Observation pipes may be located less than 6 inches from end walls or side walls if specified in state-approved manufacturers' installation instructions.
Maximum final slope of mound surface	≤ 3: 1

Note a: Letter corresponds to letters referenced in figures, formulas and on worksheets.

Table 3 OTHER SPECIFICATIONS (continued)	
Cover material	Soil that will provide frost protection, prevent erosion and excess precipitation or runoff infiltration and allow air to enter the distribution cell
Grading of surrounding area	Graded to divert surface water around mound system
Limited activities	Unless otherwise specifically allowed in this manual, vehicular traffic, excavation, and soil compaction are prohibited in the basal area and 15 feet down slope of basal area, if there is a restrictive horizon that negatively affects treatment or dispersal
Installation inspection	In accordance with ch. SPS 383, Wis. Adm. Code
Management	In accordance with ch. SPS 383, Wis. Adm. Code and this manual

I. DEFINITIONS

Definitions not found in this section, are located in ch. SPS 381 of the Wisconsin Administrative Code or the terms use the standard dictionary definition.

- A. “Basal Area” means the effective in situ soil surface area available for infiltration of partially treated effluent from the fill material.
- B. “Deflection of distribution cell” means the ratio between the maximum distance between the down slope edge of a concave distribution cell to the length of a perpendicular line that intersects the furthest points of the contour line along the down slope edge of the distribution cell.
- C. “Distribution cell area” means the area within the mound where the effluent is distributed into the fill material.
- D. “Fill Material” means sand that meets specifications of ASTM Standard C33 for fine aggregate and is used along the sides of and under the distribution cell to provide treatment of effluent.
- E. “Limiting Factor” means high groundwater elevation or bedrock.
- F. “Mound” means an on-site wastewater treatment and dispersal component. The structure contains a distribution cell area surrounded by, and elevated above, the original land surface by suitable fill material. The fill material provides a measurable degree of wastewater treatment and allows effluent dispersal into the natural environment under various soil permeability.
- G. “Original Grade” means that land elevation immediately prior to the construction of the mound system.
- H. “Parallel to surface grade contours on sloping sites” means the mound is on the contour except that a 1% cross slope is allowed along the length of the mound. See Ch. SPS 383 Appendix A-383.44 ORIENTATION (6).

- I. “Permeable Soil” means soil with textural classifications according to the U.S. Department of Agriculture, Natural Resource Conservation Service, classification system of silt loam to gravelly medium sand.
- J. “Slowly Permeable Soil” means soil with textural classifications according to the U.S. Department of Agriculture, Natural Resource Conservation Service, classification system of clay loams and silty clay loams that exhibit a moderate grade of structure; and loams, silt loams, and silts with weak grades of structure; or soils with weak to moderate grades of platy structure.
- K. “Unsaturated flow” means liquid flow through a soil media under a negative pressure potential. Liquids containing pathogens and pollutants come in direct contact with soil/fill material microsities, which enhances wastewater treatment by physical, biological, and chemical means.
- L. “Vertical Flow” means the effluent flow path downward through soil or fill material, which involves travel along soil surfaces, or through soil pores.
- M. “Vertical Separation” means the total depth of unsaturated soil that exists between the infiltrative surface of a distribution cell and limiting factor (as by redoximorphic features, groundwater or bedrock).

II. DESCRIPTION AND PRINCIPLE OF OPERATION

POWTS mound component operation is a two-stage process involving both wastewater treatment and dispersal. Treatment is accomplished predominately by physical and biochemical processes within the fill material and in situ soil. The physical characteristics of the influent wastewater, influent loading rate, temperature, and the nature of the receiving fill material and in situ soil affect these processes.

Physical entrapment, increased retention time, and conversion of pollutants in the wastewater are important treatment objectives accomplished under unsaturated conditions. Pathogens contained in the wastewater are eventually deactivated through filtering, retention, and adsorption by the fill material. In addition, many pollutants are converted to other chemical forms by oxidation processes.

Dispersal is primarily affected by the depth of the unsaturated receiving soils, their hydraulic conductivity, land slope, and the area available for dispersal.

The mound consists of fill material, a distribution cell, and cover material. Effluent is dispersed into the distribution cell where it flows through the fill material and undergoes biological, chemical, and physical treatment and then passes into the underlying soil for further treatment and dispersal to the environment.

Cover material consisting of material that provides erosion protection, a barrier to excess precipitation infiltration, and allows gas exchange. See Figure 1, for a typical mound system.

The in situ soil serves in combination with the fill, as treatment media and it also disperses the treated effluent.




Figure 1 - A cross-section-of a mound system for POWTS.

IV. SOIL AND SITE REQUIREMENTS

Every mound design is ultimately matched to the given soil and site.

The design approach presented in this manual is based on criteria that all applied wastewater is successfully transported away from the system, that it will not affect subsequent wastewater additions, and that the effluent is ultimately treated.

- A. Minimum Soil Depth Requirements - The minimum soil factors required for successful mound system performance are listed in the introduction and specification section of this package.

Soil evaluations must be in accordance with ch. SPS 385 of the Wis. Adm. Code. In addition, soil application rates must be in accordance with ch. SPS 383 of the Wis. Adm. Code.

- B. Other Site Considerations -

1. Slopes - The slope on which a mound is to be installed may not indicate the direction of groundwater movement. If there is documentation that the direction of groundwater movement is different than the slope of the land, the direction of groundwater movement must be considered during mound design.

On a crested site the fill can be situated such that the effluent can move laterally down both slopes. A level site allows lateral flow in all directions but may present problems as the water table could rise higher beneath the fill in slowly permeable soils. The sloping site allows the liquid to move in one direction away from the fill. Figure 3 shows a cross-section of a mound and the effluent movement in a slowly permeable soil on a sloping site. Systems that are installed on a concave slope may have a deflection that does not exceed that allowed in Table 2.

Mound components rely on lateral effluent movement through the upper soil horizons. Lateral movement becomes more important as soil permeability decreases.

2. Mound location - In open areas, exposure to sun and wind increases the assistance of evaporation and transpiration in the dispersal of the wastewater.
3. Sites with trees and large boulders - Generally, sites with large trees, numerous smaller trees or large boulders are less desirable for installing a mound system because of difficulty in preparing the surface and the reduced infiltration area beneath the mound. Areas that are

occupied with rock fragments, tree roots, stumps and boulders reduce the amount of soil available for proper treatment. If no other site is available, trees in the basal area of the mound must be cut off at ground level. A larger fill area is necessary when any of the above conditions are encountered, to provide sufficient infiltrative area.

4. Setback distances - The Setbacks specified in ch. SPS 383, Wis. Adm. Code for soil subsurface treatment/dispersal component apply to mound systems. The distances are measured from the up slope and end slope edge of the distribution cell and from the down slope toe of the mound. See also setback distances from toe of mound system to wells in s. NR 812.08, Table A.

V. **FILL AND COVER MATERIAL**

- A. Fill Material - The fill material and its placement are one of the most important components of the mound system. Quality control of the fill material is critical to system performance, each truckload of material must meet specifications for the fill.

Determining whether a proposed fill material is suitable or not requires that a textural analysis be performed. The standard method to be used for performing this analysis conforms to ASTM C-136, Method for Sieve Analysis of Fine and Coarse Aggregates, and ASTM E-11, Specifications for Wire-Cloth Sieves for Testing Purposes, Annual Book of ASTM Standards, Volume 04.02. Information conceiving these methods can also be obtained from Methods of Soils Analysis Part 1, C. A. Black, ed., ASA, Monograph #9, American Society of Agronomy, Inc., 1975.

- B. Cover material - The cover material is a soil that will allow air exchange while promoting plant growth. The gas exchange will increase the treatment performance of the system by providing oxygen to the wastewater to help ensure aerobic conditions in the mound system. The plant growth will provide frost protection in the winter season. Clays may not be used for cover material as they will restrict oxygen transfer. Often, excavated soil from the site can be used. Seeding or other means must be done to prevent erosion of the mound.

VI. **DESIGN**

- A. Location, Size and Shape - Placement, sizing and shaping of the mound and the distribution cell within the mound must be in accordance with this manual. The means of pressurizing the distribution network must provide equal distribution of the wastewater. A pressurized distribution network using a **method of sizing** as described in either Small Scale Waste Management Project publication 9.6, entitled “Design of Pressure Distribution Networks for Septic Tank — Soil Absorption System” or SBD-10706, entitled “Pressure Distribution Component Manual for Private Onsite Wastewater Treatment Systems” is acceptable.
- B. Component Design - Design of the mound system is based upon the design wastewater flow and the soil characteristics. It must be sized such that it can accept the design wastewater flow without causing surface seepage or groundwater pollution. Consequently, the basal area, which is the in situ soil area beneath the fill, must be sufficiently large enough to absorb the effluent into the underlying soil. The system must also be designed to avoid encroachment of the water table into the required minimum unsaturated zone.

Design of the mound includes the following three steps: (A) calculating design wastewater flow, (B) design of the distribution cell within the fill, (C) design of the entire mound. This includes calculating total width, total length, system height, distribution lateral location and observation pipes. Each step is discussed. A design example is provided in section XI of the manual. The letters for the various dimensions correlate with those in Figures 2 and 3.

Step A. Design Wastewater Flow Calculations

One- and two-family dwellings. Distribution cell size for one and two-family dwelling application is determined by calculating the design wastewater flow (DWF). To calculate DWF use, Formulas 1, 2 or 3. Formula 1 is for combined wastewater flows, which consist of blackwater, clear water and graywater. Formula 2 is for only clearwater and graywater. Formula 3 is blackwater only.

Formula 1 Combined wastewater DWF = 150 gal/day/bedroom	Formula 2 Clearwater & Graywater DWF = 90 gal/day/bedroom	Formula 3 Blackwater DWF = 60 gal/day/bedroom
---	---	---

Public Facilities. Distribution cell size for public facilities application is determined by calculating the DWF using Formula 4. Public facility estimated daily wastewater flows can be found in s. SPS 383.43(6), Wis. Adm. Code. Facilities not listed in s. SPS 383.43(6), Wis. Adm. Code can be discussed with the plan reviewer to establish an acceptable daily flow rate volume. Many commercial facilities have high BOD₅, TSS and FOG (fats, oils and grease), which must be pretreated in order to bring their values down to an acceptable range before entering into the mound component described in this manual.

Formula 4

$$DWF = \text{Sum of each estimated wastewater flow per source per day} \times 1.5$$

Where 1.5 = Conversion factor to convert estimated wastewater flow to design wastewater flow

Step B. Design of the Distribution Cell - This section determines the required infiltrative surface area of the distribution cell/fill interface, as well as the dimensions of the distribution network within the fill.

1. Sizing the Distribution Cell - The minimum bottom area of the distribution cell is determined by dividing the design wastewater flow per day by the design loading rate of the fill material. As specified in Table 1, the design loading rate of the infiltration surface of the distribution cell is:

$\leq 1.0 \text{ gal/ft}^2/\text{day}$ if BOD_5 or $\text{TSS} > 30 \text{ mg/L}$ or

$\leq 2.0 \text{ gal/ft}^2/\text{day}$ if BOD_5 or $\text{TSS} \leq 30 \text{ mg/L}$

Using the above information, the infiltrative surface area of the distribution cell area is determined by using Formula 5.

Formula 5

Area = DWF \div design loading rate of the fill material.

For concave systems the actual distribution cell length must be checked to determine if the cell area is sufficient. See Step B 3 for further information.




Figure 2 - Detailed plan view of a mound.

(For location of observation pipes, see IV. DESIGN, Step C 7.)




Figure 3 - Detailed cross-section of a mound.

2. System Configuration - The distribution cell must be longer than it is wide. Maximum width of the distribution cell is 10 feet. The maximum length of the distribution cell is dependent on setback requirements and soil evaluation.

The distribution cell is aligned with its longest dimension parallel to surface grade contours on sloping sites as required by the specifications of this package so as not to concentrate the effluent into a small area as it moves laterally down slope.

The bottom of the distribution cell is level so one area of the distribution cell is not overloaded.

The dimensions for the distribution cell are calculated using Formulas 6 or 7. Formula 6 is used when the in situ soil has a soil application rate of greater than 0.3 gal/ft²/day. Formula 7 must be used to check for linear loading rate for the system when the in situ soil within 12 inches of the fill material has a soil application rate of ≤ 0.3 gal/ft²/day. When the in situ soil within 12 inches of the fill material has a soil application rate of ≤ 0.3 gal/ft²/day the linear loading rate may not exceed 4.5 gal/ft/day.

Formula 6

$$\text{Area of distribution cell} = A \times B.$$

Where: A = Distribution cell width (Max. allowed is 10 ft.)

B = Distribution cell length

Formula 7

$$\text{Linear Loading Rate} = \text{DWF} \div B$$

Where: DWF = Design wastewater flow

B = Distribution cell length

Step C. Sizing the Mound

1. Mound Height - The mound height on sloping sites is calculated using Formula 10.

Formula 10

$$\text{Mound Height} = (D + E) \div 2 + F + H$$

Where: D = Sand fill depth
E = Down slope fill depth
F = Distribution cell depth
H = Cover material depth

2. Fill Depth - The depth of fill under the distribution cell is based on the minimum depth of unsaturated soil required for treatment listed in Table 383.44-3, Wis. Adm. Code. The minimum fill depth is 6 inches, but not greater than 36 inches when the soil listed in Table 383.44-3, Wis. Adm. Code, is 36 inches or less. The minimum fill depth is 12 inches, but not greater than 36 inches when the soil listed in Table 383.44-3, Wis. Adm. Code, is greater than 36 inches. A minimum unsaturated flow depth required for proper treatment of the wastewater is as required by Table 383.44-3, Wis. Adm. Code.

For sloping sites the fill depth below down slope edge of distribution cell (E) $\geq D +$ [% slope of original grade as a decimal x width of distribution cell (A)]

3. Distribution Cell Depth - The distribution cell depth (F) provides wastewater storage within the distribution cell. A minimum depth includes 6 inches beneath the distribution pipe and approximately 2 inches above the distribution piping, as stated in the specification section of this manual. This space may be provided with the use of stone aggregate or leaching chambers. To calculate the minimum cell depth, use Formula 11.

Formula 11

$$\text{Distribution cell depth (F)} = 8 \text{ inches} + \text{nominal pipe size of distribution lateral}$$

4. Cover Material - The cover material (G & H) provides frost protection and a suitable growth medium for vegetation. For design purposes, use a depth of 12 inches above the center of the distribution cell (H) and 6 inches above the outer edge of the distribution cell (G).

Cover material depth at distribution cell center (H) ≥ 12 inches

Cover material depth at distribution cell edges (G) ≥ 6 inches

5. Fill Length and Width - The length and width of the fill are dependent upon the length and width of the distribution cell, fill depth and side slopes of the fill. Side slopes may not be steeper than 3:1 over the basal area, (i.e. 3 feet of run to every 1 foot of rise). Soil having textures other than those specified for the fill media may be used to make the slopes gentler than the required 3:1 slopes, once the 3:1 slope exists with the fill material. The distribution cell length is generally perpendicular to

the direction of slope so the effluent is spread out along the contour.

The fill length consists of the end slopes (K) and the distribution cell length (B). The fill width consists of the up slope width (J), the distribution cell width (A), and the down slope width (I). On sloping sites the up slope width (J) is less while the down slope width (I) is greater than on a level site to maintain the 3:1 side slope (see Fig. 2). To calculate the up slope and down slope widths when a 3:1 side slope is maintained, multiply the calculated width by the correction factor found by using the following equations or the correction factor listed in Table 5.

Up slope correction factor = $100 \div [100 + (3 \times \% \text{ of slope})]$

Down slope correction factor = $100 \div [100 - (3 \times \% \text{ of slope})]$

Slope %	Down slope correction factor	Up Slope correction factor
0	1.00	1.00
1	1.03	0.97
2	1.06	0.94
3	1.06	0.915
4	1.14	0.89
5	1.18	0.875
6	1.22	0.85
7	1.27	0.83
8	1.32	0.81
9	1.37	0.79
10	1.43	0.77
11	1.49	0.75
12	1.56	0.735
13	1.64	0.72
14	1.72	0.705
15	1.82	0.69
16	1.92	0.675
17	2.04	0.66
18	2.17	0.65
19	2.33	0.64
20	2.50	0.625
21	2.70	0.61
22	2.94	0.60
23	3.23	0.59
24	3.57	0.58
25	4.00	0.57

The most critical dimensions of the fill are: fill depths (D) & (E), distribution cell length (B), distribution cell width (A), and the down slope width (I).

End slope width (K) = Total fill at center of distribution cell $\{(D + E) \div 2\} + F + H$
x horizontal gradient of selected side slope (3 if 3:1 side-slope)

Fill Length (L) = Distribution cell length (B) + 2 x end slope width (K)

Up slope width (J) — Fill depth at up slope edge of distribution cell $(D + F + G)$ x horizontal gradient of side slope (3 if 3:1) x slope correction factor $\{100 \div [100 + (3 \times \% \text{ of slope})]\}$ if 3:1}

Down slope width (I) = Fill depth at down slope edge of distribution cell $(E + F + G)$ x horizontal gradient of side slope (3 if 3:1) x slope connection factor $\{100 \div [100 - (3 \times \% \text{ of slope})]\}$ if 3:1}

$\text{Fill Width (W)} = \text{Up slope width (J)} + \text{down slope width (I)} + \text{width of distribution cell (A)}$

These calculations result in the fill material extending at least 6 inches horizontally from the top edges of the distribution cell as noted in Figure 6.




Figure 6 Cross-section of a Mound System

6. **Basal Area** - The basal area is the in situ soil/fill interface between the soil and the fill material. Its function is to accept the effluent from the fill, assist the fill in treating the effluent, and transfer the effluent to the subsoil beneath the fill or laterally to the subsoil outside of the fill.

The soil infiltration rate of the in situ soil determines how much basal area is required. When the wastewater applied to the mound has values for BOD₅ and TSS of ≤ 30 mg/L or if there is at least 12 inches of fill material beneath the distribution cell the soil application rates for the basal area may be those specified in Table 383.44-1 or -2 for maximum monthly average BOD₅ and TSS of ≤ 30 mg/L.

For level sites, the total basal area, excluding end slope area [length of distribution cell

(B) x width of fill and cover (W)] beneath the fill and soil cover is available for effluent absorption into the soil (see Figure 7a). For sloping sites, the available basal area is the area down slope of the up slope edge of the distribution cell to the down slope edge of the fill and soil cover or (A + I) times the length of the distribution cell (B) (see Figure 7b). The up slope width and end slopes are not included as part of the total basal area.

It is important to compare the required basal area to the available basal area. The available basal area must equal or exceed the required basal area.




Figure 7a Level Site




Figure 7b One direction slope

Basal area required = $DWF \div \text{Infiltration rate of in situ soil}$

Basal area available = $B \times W$ on a level site or = $B \times (A+I)$ on a sloping site.

If sufficient area is not available for the given design and site conditions, corrective action is required to increase (J) and (I) on level sites or (I) on sloping sites.

7. Location of the observation pipes.

Observation pipes will be installed in each distribution cell so as to be representative of a cell's hydraulic performance.

- be located such that there are a minimum of two installed in each dispersal cell at opposite ends from one another
- be located near the dispersal cell ends
- be at least 6 inches from the end wall and sidewall
- be installed at an elevation to view the horizontal or level infiltrative surface within the dispersal cell

Observation pipes may be located less than 6 inches from end walls or side walls if specified in state approved manufacturers' installation instructions.

Step D. Distribution Network and Dosing System A pressurized distribution network based on a **method of sizing** as described in either Small Scale Waste Management Project publication 9.6, entitled "Design of Pressure Distribution Networks for Septic Tank — Soil Absorption Systems" or Dept. of Safety and Professional Services publication SBD-10706, entitled "Pressure Distribution Component Manual for Private Onsite Wastewater Treatment Systems" is acceptable.

VII. SITE PREPARATION AND CONSTRUCTION

Procedures used in the construction of a mound system are just as critical as the design of the system. A good design with poor construction results in system failure. It is emphasized that the soil only be tilled when it is not frozen, and the moisture content is low to avoid compaction and puddling. The construction plan to be followed includes:

- A. Equipment - Proper equipment is essential. Track type tractors or other equipment that will not compact the mound area or the down slope area are required.
- B. Sanitary Permit - Prior to the construction of the system, a sanitary permit, obtained for the installation must be posted in a clearly visible location on the site. Arrangements for inspection(s) must also be made with the department or governmental unit issuing the sanitary permit.
- C. Construction Procedures
 1. Check the moisture content of the soil to a depth of 8 inches. Smearing and compacting of wet soil will result in reducing the infiltration capacity of the soil. Proper soil moisture content can be determined by rolling a soil sample between the hands. If it rolls into a 1/4- inch wire, the site is too wet to prepare. If it crumbles, site preparation can proceed. If the site is too wet to prepare, do not proceed until it dries.
 2. Lay out the fill area on the site so that the distribution cell runs perpendicular to the direction of the slope.
 3. Establish the original grade elevation (surface contour) along the up slope edge of the distribution cell. This elevation is used throughout the mound construction as a reference to determine the bottom of the distribution cell, lateral elevations, etc., and is referenced to the permanent benchmark for the project. A maximum of 6 inches of sand fill may be tilled into the surface.
 4. Determine where the force main from the dosing chamber will connect to the distribution system in the distribution cell. Place the pipe either before tilting or after placement of the fill. If the force main is to be installed in the down slope area, the trench for the force main may not be wider than 12 inches.
 5. Cut trees flush to the ground and leave stumps, remove surface boulders that can be easily rolled off, remove vegetation over 6 inches long by mowing and removing cut vegetation. Prepare the site by breaking up, perpendicular to the slope, the top 7-8 inches so as to eliminate any surface mat that could impede the vertical flow of liquid into the in situ soil. When using a moldboard plow, it should have as many bottoms as possible to reduce the number of passes over the area to be tilled and minimize compaction of the subsoil. Tilling with a moldboard plow is done along contours. Chisel type plowing is highly recommended especially in fine textured soils. Rototilling (or other means that pulverize the soil) and use of a frost tooth are not acceptable. The important point is that a rough, unsmearred surface be left. The sand fill will intermingle between the clods of soil, which improves the infiltration rate into the natural soil.

Immediate application of at least 6 inches of fill material is required after tilling. All vehicular traffic is prohibited on the tilled area. For sites where the effluent may move laterally, vehicle traffic is also prohibited for 15 ft. down slope, and 10 ft. on both sides of level sites. If it rains after the tilling is completed, wait until the soil dries out before

continuing construction, and contact the local inspector for a determination on the damage done by rainfall.

6. Place the approved sand fill material, around the edge of the tilled area being careful to leave adequate perimeter area, not covered by the sand fill, on which to place the soil cover. There should be approximately two feet of basal area adjacent to the mound perimeter that is not covered by the sand fill. This area serves to tie the soil cover into the natural surface material that has been tilled and helps seal the toe from leakage. Work from the end and up slope sides. This will avoid compacting the soils on the down slope side, which, if compacted, affects lateral movement away from the fill and could cause surface seepage at the toe of the fill on slowly permeable soils.
7. Move the fill material into place using a small track type tractor with a blade or a large backhoe that has sufficient reach to prevent compaction of the tilled area. Do not use a tractor/backhoe having tires. Always keep a minimum of 6 inches of fill material beneath tracks to prevent compaction of the in situ soil.
8. Place the fill material to the required depth.
9. Form the distribution cell. Hand level the bottom of the distribution cell. If using leaching chambers, hand tamp fill where chambers will be located.

NOTE: If using leaching chambers go to step 15.

10. Install the required observation pipes with the bottom 6 inches of the observation pipe slotted. Installations of all observation pipes include a suitable means of anchoring. See Figure 8.
11. Place the stone aggregate in the distribution cell. Level the stone aggregate to the design depth.




Figure 8 – Observation Pipes

12. Shape the sides with additional fill to the desired slopes.
13. Place the effluent distribution lateral(s), as determined from the pressure distribution design, on the stone aggregate. Connect the lateral(s) using the needed connections and piping to the force main pipe from the dosing chamber. Slope the piping from the lateral(s) to the force main pipe. Lay the effluent distribution lateral(s) level. All pipes must drain after dosing.

14. Place stone aggregate over the distribution network and the entire distribution cell until the elevation of the stone aggregate is at least 2 inches above the top of the distribution network.

NOTE: If using stone aggregate go to step 17.

15. Install the leaching chambers and pressure distribution piping as instructed by the leaching chamber manufacturer's instructions, pressure distribution design and applicable sections of ch. SPS 382, 383 and 384, Wis. Adm. Code.
16. Install an observation pipe in each row of leaching chambers.
17. If stone aggregate is used, place geotextile fabric conforming to requirements of ch. SPS 384, Wis. Adm. Code, over the stone aggregate.
18. Place cover material on the top of the geotextile fabric and extend the soil cover to the boundaries of the overall component.
19. Complete final grading to divert surface water drainage away from mound. Sod or seed and mulch the entire mound component.

VIII. OPERATION, MAINTENANCE AND PERFORMANCE MONITORING

- A. The component owner is responsible for the operation and maintenance of the component. The county, department or POWTS service contractor may make periodic inspections of the components, checking for surface discharge, treated effluent levels, etc.

The owner or owner's agent is required to submit necessary maintenance reports to the appropriate jurisdiction and/or the department.
- B. Design approval and site inspections before, during, and after the construction are accomplished by the county or other appropriate jurisdictions in accordance to ch. SPS 383 of the Wis. Adm. Code.
- C. Routine and preventative maintenance aspects:
 1. Treatment and distribution tanks are to be inspected routinely and maintained when necessary, in accordance with their approvals.
 2. Inspections of the mound component performance are required at least once every three years. These inspections include checking the liquid levels in the observation pipes and examination for any seepage around the mound component.
 3. Winter traffic on the mound is not advised to avoid frost penetration and to minimize compaction.
 4. A good water conservation plan within the house or establishment will help assure that the mound component will not be overloaded.

- D. User's Manual: A user's manual is to accompany the component. The manual is to contain the following as a minimum:
1. Diagrams of all components and their location. This should include the location of the reserve area, if one is provided.
 2. Names and phone numbers of local health authority, component manufacturer or POWTS service contractor to be contacted in the event of component failure *or* malfunction.
 3. Information on periodic maintenance of the component, including electrical/mechanical components.
 4. Information on limited activities on reserve area if provided.
- E. Performance monitoring must be performed on mound systems installed under this manual.
1. The frequency of monitoring must be:
 - a. At least once every three years following installation and,
 - b. At time of problem, complaint, or failure.
 2. The minimum criteria addressed in performance monitoring of mound systems are:
 - a. Type of use.
 - b. Age of system.
 - c. Nuisance factors, such as odors or user complaints.
 - d. Mechanical malfunction within the system including problems with valves or other mechanical or plumbing components.
 - e. Material fatigue or failure, including durability or corrosion as related to construction or structural design.
 - f. Neglect or improper use, such as exceeding the design rate, poor maintenance of vegetative cover, inappropriate cover over the mound, or inappropriate activity over the mound.
 - g. Installation problems such as compaction or displacement of soil, improper orientation, or location.
 - h. Pretreatment component maintenance, including dosing frequency, structural integrity, groundwater intrusion or improper sizing.
 - i. Dose chamber maintenance, including improper maintenance, infiltration, structural problems, or improper sizing.
 - j. Distribution piping network, including improper maintenance or improper sizing.
 - k. Ponding in distribution cell, prior to the pump cycle, is evidence of development of a clogging mat or reduced infiltration rates.
 - l. Siphon or pump malfunction including dosing volume problems, pressurization problems, breakdown, burnout, or cycling problems.
 - m. Overflow/seepage problems, as shown by evident or confirmed sewage effluent, including backup if due to clogging.

4. Reports are to be submitted in accordance with ch. SPS 383, Wis. Adm. Code..

IX. REFERENCES

“Wisconsin Mound Soil Absorption System: Siting, Design and Construction.” Converse, J.C., and E. J. Tyler. Publication 15.22, Small Scale Waste Management Project., 1 Agriculture Hall, University of Wisconsin, Madison, WI.

Blackwater only:

$$\begin{aligned} \text{DWF} &= 60 \text{ gal/day/bedroom} \times \# \text{ of bedrooms} \\ &= 60 \text{ gal/day/bedroom} \times \underline{\hspace{2cm}} \# \text{ of bedrooms} \\ &= \underline{\hspace{2cm}} \text{ gal/day} \end{aligned}$$

Public Facilities

$$\begin{aligned} \text{DWF} &= \text{Estimated wastewater flow} \times 1.5 \\ &= \underline{\hspace{2cm}} \text{ gal/day} \times 1.5 \\ &= \underline{\hspace{2cm}} \text{ gal/day} \end{aligned}$$

C. DESIGN OF THE DISTRIBUTION CELL

1. Total size of the Distribution Cell(s) area

- a. Loading rate of fill material = $\leq 1.0 \text{ gal/ft}^2/\text{day}$ if BOD_5 or $\text{TSS} > 30 \text{ mg/L}$ or
 $\leq 2.0 \text{ gal/ft}^2/\text{day}$ if BOD_5 or $\text{TSS} \leq 30 \text{ mg/L}$
- b. Bottom area of total distribution cell area = Design wastewater flow \div loading rate of fill as determined in C.1.a.

$$\text{Distribution cell area} = \underline{\hspace{2cm}} \text{ gal/day} \div \underline{\hspace{2cm}} \text{ gal/ft}^2/\text{day}$$

$$\text{Distribution cell area} = \underline{\hspace{2cm}} \text{ ft}^2$$

2. Distribution Cell Configuration

- a. Distribution cell width(s) (A) = $\underline{\hspace{2cm}}$ feet (≤ 10 ft.) and number of distribution cells = $\underline{\hspace{2cm}}$ cells
- b. Distribution cell length (B) = Bottom area of distribution cell \div width of distribution cell
 $B = \underline{\hspace{2cm}} \text{ ft}^2$ (Distribution cell area required) \div $\underline{\hspace{2cm}}$ ft(A)
 $B = \underline{\hspace{2cm}}$ ft
- c. Check Distribution Cell Length (B)

For linear loading rate:

Linear Loading Rate \leq Design Wastewater Flow \div Cell length (B) or effective cell length for a concave mound

$$\text{Linear Loading Rate} \leq \underline{\hspace{2cm}} \text{ gal/day} \div \underline{\hspace{2cm}} \text{ feet}$$

$$\text{Linear Loading Rate} \leq \underline{\hspace{2cm}} \text{ gal/ft/day}$$

Linear loading rate for systems with in situ soils having a soil application rate of ≤ 0.3 gal/ft²/day within 12 inches of fill must be less than or equal to 4.5 gal/ft/day.

Is the linear loading rate \leq what is allowed? ___Yes ___No If no, then the length and width of the distribution cell must be changed so it does.

Distribution cell length (B) = Design Wastewater Flow \div Maximum Linear Loading Rate

Distribution cell length (B) = _____ gal/day \div _____ gal/ft/day

Distribution cell length (B) = _____ ft

Distribution cell total width (A) = _____ ft² (Distribution cell area) \div _____ ft(B)

Distribution cell total width (A) = _____ ft

D. DESIGN OF ENTIRE MOUND AREA

1. Fill Depth

- a. Fill depth below distribution cell must be at least 6 inches, but not greater than 36 inches. If the in situ soil beneath the tilled area is a soil listed in Table 383.44-3, Wis. Adm. Code, that requires a minimum depth of 36 inches or less. At least 12 inches, but not greater than 36 inches if the in situ soil beneath the tilled area is a soil listed in Table 383.44-3, Wis. Adm. Code, that requires a depth greater than 36 inches.

- 1) Depth at up slope edge of distribution cell (D) = distance required by Table 383.44-3, Wis. Adm. Code, minus distance in inches to limiting factor

D = _____ inches - _____ inches

D = _____ inches (at least ≥ 6 or 12 inches, but not greater than 36 inches in accordance with Table 2)

- 2) Depth at down slope edge of distribution cell (E)

E = Depth at up slope edge of distribution cell (D) + (% natural slope expressed as a decimal x distribution cell width (A))

E = D + (% natural slope expressed as decimal x A)

E = _____ inches + (_____ x _____ feet x 12 inches/ft)

E = _____ inches

b. Distribution cell Depth for Stone Aggregate Distribution cell.

Distribution cell depth (F) for stone aggregate distribution cell = amount of stone aggregate below distribution laterals (6 inches min.) + nominal pipe size of largest lateral + amount of stone aggregate over distribution laterals (2 inches min.).

$$F = \text{___} (\geq 6) \text{ inches} + \text{___} \text{ inches} + \text{___} (\geq 2) \text{ inches}$$

$$F = \text{_____} \text{ inches}$$

c. Distribution cell depth (F) for distribution cell with leaching chambers = total height of leaching chamber.

$$F = \text{_____} \text{ inches}$$

d. Cover material

1) Depth at center of distribution cell area (H) \geq 12 inches

2) Depth at outer edges of distribution cell area (G) \geq 6 inches

2. Mound length

a. End slope width (K) = Total fill at center of distribution cell x horizontal gradient of side slope

$$K = \{([D + E] \div 2) + F + H\} \times \text{horizontal gradient of side slope} \div 12 \text{ inches/foot}$$

$$K = \{([\text{___} \text{ inches} + \text{_____} \text{ inches}] \div 2) + \text{___} \text{ inches} + \text{_____} \text{ inches}\} \times \text{___} \div 12 \text{ inches/ft}$$

$$K = \text{_____} \text{ ft}$$

b. Mound length (L) = Distribution cell length + (2 x end slope width)

$$L = B + 2K$$

$$L = \text{_____ ft} + (2 \times \text{_____ ft})$$

$$L = \text{_____ feet}$$

3. Mound width

a. Up slope width (J) = Fill depth at up slope edge of distribution cell (D + F + G) x Horizontal gradient of side slope x Slope correction factor {100 ÷ [100 + (gradient of side slope x % of slope) or (value from Table 5)]}

$$J = (D + F + G) \times \text{horizontal gradient of side slope} \times \text{slope correction factor } 100 \div [100 + (\text{gradient of side slope} \times \% \text{ of slope}) \text{ or (value from Table 5)}]$$

$$J = (\text{_____ in} + \text{_____ in} + \text{_____ in}) \div 12 \text{ in/ft} \times \text{_____} \times 100 \div [100 + (\text{_____} \times \text{_____})] \text{ or } [\text{_____}]$$

$$J = \text{_____ feet}$$

b. Down slope width (I) = Fill depth at down slope edge of distribution cell (E + F + G) x Horizontal gradient of side slope x Down slope correction factor {100 ÷ [100 - (gradient of side slope x % of slope) or (value from Table 5)]}

$$I = (E + F + G) \times \text{Horizontal gradient of side slope} \times \text{Down slope correction factor } \{100 \div [100 - (\text{gradient of side slope} \times \% \text{ of slope}) \text{ or (value from Table 5)}]\}$$

$$I = (\text{_____ in} + \text{_____ in} + \text{_____ in}) \div 12 \text{ in/ft} \times \text{_____} \times 100 \div [100 - (\text{_____} \times \text{_____})] \text{ or } [\text{_____}]$$

$$I = \text{_____ in} \div 12 \text{ in/ft} \times 3 \times 100 \div \text{_____}$$

$$I = \text{_____ feet}$$

c. Mound width (W) = Up slope width (J) + Distribution cell width (A) + Down slope width (I)

$$W = J + A + I$$

$$W = \text{_____ ft} + \text{_____ ft} + \text{_____ ft}$$

$$W = \text{_____ feet}$$

4. Check the basal area

- a. Basal area required = Daily wastewater flow ÷ soil application rate of in situ soil (The soil application rate may be that which is listed for BOD₅ and TSS > or ≤ 30 mg/L depending on wastewater characteristics or fill depth below distribution cell. See Table 1.)

$$= \text{_____ gal/day} \div \text{_____ gal/ft}^2/\text{day}$$

$$= \text{_____ ft}^2$$

b. Basal area available

- 1) Sloping site = Cell length (B) x [(# of cells x cell width) + ({# of cells — 1} x cell spacing) + down slope width] (A+I)

$$= \text{_____ ft} \times [(\text{_____} \times \text{_____ ft}) + (\{\text{_____} - 1\} \times \text{_____ ft}) + \text{_____ ft}]$$

$$- \text{_____ ft} \times (\text{_____ ft} + \text{_____ ft} + \text{_____ ft})$$

$$- \text{_____ ft} \times \text{_____ ft}$$

$$- \text{_____ ft}^2$$

- 2) Level site = Cell length (B) x total mound width (W)

$$= \text{_____ ft} \times \text{_____ ft}$$

$$= \text{_____ ft}^2$$

- c. Is available basal area sufficient? yes no

Basal area required ≤ Basal area available

$$\text{_____ ft}^2 \leq \text{_____ ft}^2$$

See d. for recalculation of basal area

d. Basal area available (recalculation of basal area)

1) Sloping site = Cell length (B) x [(# of cells x cell width) + ({# of cells — 1} x cell spacing) + down slope width] (A+I)

$$\begin{aligned} &= \text{_____ ft x [(__ x __ ft) + (\{__ - 1\} x __ ft) + __ ft]} \\ &- \text{_____ ft x (__ ft + __ ft + __ ft)} \\ &- \text{_____ ft x __ ft} \\ &- \text{_____ ft}^2 \end{aligned}$$

2) Level site = Cell length (B) x total mound width (W)

$$\begin{aligned} &= \text{_____ ft x __ ft} \\ &= \text{_____ ft}^2 \end{aligned}$$

5. Determine the location of observation pipes along the length of distribution cell.

Observation pipes will be installed in each distribution cell so as to be representative of a cell's hydraulic performance.

- be located such that there are a minimum of two installed in each dispersal cell at opposite ends from one another
- be located near the dispersal cell ends
- be at least 6 inches from the end wall and sidewall
- be installed at an elevation to view the horizontal or level infiltrative surface within the dispersal cell

Observation pipes may be located less than 6 inches from end walls or side walls if specified in state—approved manufacturers' installation instructions.

XI. EXAMPLE WORKSHEET

A. SITE CONDITIONS

Evaluate the site and soils report for the following:

- Surface water movement.
- Measure elevations and distances on the site so that slope, contours and available areas can be determined.
- Description of several soil profiles where the component will be located.
- Determine the limiting conditions such as bedrock, high groundwater level, soil permeability, and setbacks.

Slope - 6 %

Occupancy - One or Two-Family Dwelling - 3 (# of bedrooms)

Public Facility - 0 gal/day (Estimated wastewater flow)

Depth to limiting factor - 25 inches

Minimum depth of unsaturated soil required by Table 383.44-3, Wis. Adm. Code - 36 inches

In situ soil application rate used - 0.3 gal/ft²/day

FOG value of effluent applied to component - < 30 mg/L

BOD₅ value of effluent applied to component - 180 mg/L

TSS value of effluent applied to component - 50 mg/L

Fecal Coliform monthly geometric mean value of effluent applied to component > 10⁴ cfu/100ml X Yes No

Type of distribution cell - X Stone aggregate or Leaching chamber

B. DESIGN WASTEWATER FLOW (DWF)

One or Two-family Dwelling

Combined wastewater flow:

$$\begin{aligned} \text{DWF} &= 150 \text{ gal/day/bedroom} \times \# \text{ of bedrooms} \\ &= 150 \text{ gal/day/bedroom} \times \underline{3} \# \text{ of bedrooms} \\ &= 450 \text{ gal/day} \end{aligned}$$

Clear water and graywater only:

$$\begin{aligned} \text{DWF} &= 90 \text{ gal/day/bedroom} \times \# \text{ of bedrooms} \\ &= 90 \text{ gal/day/bedroom} \times \underline{\quad\quad} \# \text{ of bedrooms} \\ &= \underline{\quad\quad\quad} \text{ gal/day} \end{aligned}$$

Blackwater only:

$$\begin{aligned} \text{DWF} &= 60 \text{ gal/day/bedroom} \times \# \text{ of bedrooms} \\ &= 60 \text{ gal/day/bedroom} \times \underline{\quad\quad} \# \text{ of bedrooms} \\ &= \underline{\quad\quad\quad} \text{ gal/day} \end{aligned}$$

Public Facilities

$$\begin{aligned} \text{DWF} &= \text{Estimated wastewater flow} \times 1.5 \\ &= \underline{\quad\quad\quad} \text{ gal/day} \times 1.5 \\ &= \underline{\quad\quad\quad} \text{ gal/day} \end{aligned}$$

C. DESIGN OF THE DISTRIBUTION CELL

1. Total size the Distribution cell(s) area

a. Loading rate of fill material = $\frac{X}{\quad\quad} \leq 1.0 \text{ gal/ft}^2/\text{day}$ if BOD₅ or TSS > 30 mg/L or $\frac{\quad\quad}{\quad\quad} \leq 2.0 \text{ gal/ft}^2/\text{day}$ if BOD₅ or TSS ≤ 30 mg/L

a. Bottom area of distribution cell = Design wastewater flow ÷ loading rate of fill material a determined in C.1.a.

$$\text{Distribution cell area} = \frac{450 \text{ gal/day}}{1.0 \text{ gal/ft}^2/\text{day}}$$

$$\text{Distribution cell area} = \underline{450} \text{ ft}^2$$

2. Distribution cell Configuration

a. Distribution cell width(s) (A) = 7 feet (≤10 ft.) and the number of distribution cells = 1 cells

b. Distribution cell length (B) = Bottom area of distribution cell ÷ width of distribution cell

$$B = \frac{450 \text{ ft}^2 \text{ (Distribution cell area required)}}{7 \text{ ft(A)}}$$

$$B = \underline{64.29} \text{ or } \underline{65} \text{ ft}$$

c. Check distribution cell length (B)

For linear loading rate:

Linear Loading Rate ≤ Design Wastewater Flow ÷ Cell length (B) or effective cell length for a concave mound

$$\text{Linear Loading Rate} \leq \frac{450 \text{ gal/day}}{65 \text{ ft}}$$

$$\text{Linear Loading Rate} \leq \underline{6.92} \text{ gal/ft}$$

Linear loading rate for systems with in situ soils having an soil application rate of ≤ 0.3 gal./ft²/day within 12 inches of fill must be less ≤ 4.5 gal/ft/day.

Is the linear loading rate \leq what is allowed? Yes X No If no, then the length and/or width of the distribution cell must be changed so it does.

Distribution cell length (B) = Design Wastewater Flow \div Maximum Linear Loading Rate

Distribution cell length (B) = 450 gal/day \div 4.5 gal/ft/day

Distribution cell length (B) = 100 ft

Distribution cell width (A) = 450 ft² (Distribution cell area) \div 100 ft (B)

Distribution cell width (A) = 4.5 ft²

D. DESIGN OF ENTIRE MOUND AREA

1. Fill Depth

- a. Minimum fill depth below distribution cell At least 6 inches, but not greater than 36 inches if the in situ soil beneath the tilled area is a soil listed in Table 383.44-3, Wis. Adm. Code, that requires a minimum depth of 36 inches or less. At least 12 inches, but not greater than 36 inches if the in situ soil beneath the tilled area is a soil listed in Table 383.44-3, Wis. Adm. Code, that requires a depth greater than 36 inches.

1) Depth at up slope edge of distribution cell (D) = distance required by Table 383.44-3, Wis. Adm. Code, minus distance in inches to limiting factor

D = 36 inches - 25 inches

D = 11 inches (at least \geq 6 or 12 inches, but not greater than 36 inches in accordance with Table 2)

2) Depth at down slope edge of distribution cell (E)

E = Depth at up slope edge of distribution cell (D) + (% natural slope expressed as a decimal x distribution cell width (A))

E = D + (% natural slope expressed as decimal x A)

E = 11 inches + (0.06 x 4.5 feet x 12 inches/ft)

E = 14.24 or 14.25 inches

- b. Distribution cell Depth for Stone Aggregate Distribution cell.

Distribution cell depth (F) for stone aggregate distribution cell = amount of stone aggregate below distribution laterals (6 inches min.) + nominal outside diameter of largest lateral + amount of stone aggregate over distribution laterals (2 inches min.).

F = 6 (\geq 6) inches + 1.5 inches + 2 (\geq 2) inches

F = 9.5 inches

- c. Distribution cell depth (F) for distribution cell with leaching chambers = total height of leaching chamber.

$$F = \underline{\hspace{2cm}} \text{ inches}$$

- d. Cover material

1) Depth at distribution cell center (H) \geq 12 inches

2) Depth at distribution cell edges (G) \geq 6 inches

2. Mound length

- a. End slope width (K) = Total fill at center of distribution cell x horizontal gradient of side slope

$$K = \{[(D + E) \div 2] + F + H\} \times \text{horizontal gradient of side slope} \div 12 \text{ inches/foot}$$

$$K = \{[(\underline{11} \text{ inches} + \underline{14.25} \text{ inches}) \div 2] + \underline{9.5} \text{ inches} + \underline{12} \text{ inches}\} \times \underline{3} \div 12 \text{ inches/ft}$$

$$K = \underline{8.53} \text{ or } \underline{8.5} \text{ ft}$$

- b. Mound length (L) = Distribution cell length + (2 x end slope width)

$$L = B + 2K$$

$$L = \underline{100} \text{ ft} + (2 \times \underline{8.5} \text{ ft})$$

$$L = 117 \text{ feet}$$

3. Mound width

- a. Up slope width (J) = Fill depth at up slope edge of distribution cell (D + F + G) x Horizontal gradient of side slope x Slope correction factor $\{100 \div [100 + (\text{gradient of side slope} \times \% \text{ of slope or value from Table 5})]\}$

$$J = (D + F + G) \times \text{horizontal gradient of side slope} \times \text{Slope correction factor} \{100 \div [100 + (\text{gradient of side slope} \times \% \text{ of slope or value from Table 5})]\}$$

$$J = (\underline{11} \text{ in} + \underline{9.5} \text{ in} + \underline{6} \text{ in}) \div 12 \text{ in/ft} \times \underline{3} \times 100 \div [100 + (\underline{3} \times \underline{6})] \text{ or } [\underline{\hspace{1cm}}]$$

$$J = \underline{5.61} \text{ or } \underline{5.6} \text{ feet}$$

- b. Down slope width (I) = Fill depth at down slope edge of distribution cell (E + F + G) x Horizontal gradient of side slope x Down slope correction factor $\{100 \div [100 - (\text{gradient of side slope} \times \% \text{ of slope or value from Table 5})]\}$

$I = (E + F + G) \times \text{Horizontal gradient of side slope} \times \text{Down slope correction factor}$
 $\{100 \div [100 - (\text{gradient of side slope} \times \% \text{ of slope or value from Table 5})]\}$

$$I = \underline{14.25} \text{ in} + \underline{9.5} \text{ in} + \underline{6} \text{ in} \div 12 \text{ in/ft} \times 3 \times 100 \div [100 - (\underline{3} \times \underline{6})]$$

$$I = \underline{29.75} \text{ in} + 12 \text{ in/ft} \times 3 \times 100 \div \underline{82}$$

$$I = \underline{9.07} \text{ or } \underline{9.1} \text{ feet}$$

c. Mound width (W) = Up slope width (J) + Distribution cell width (A) + Down slope width (I)

$$W = J + A + I$$

$$W = \underline{5.6} \text{ ft} + \underline{4.5} \text{ ft} + \underline{9.1} \text{ ft}$$

$$W = \underline{19.2} \text{ feet}$$

4. Check the basal area

a. Basal area required = Daily wastewater flow \div soil application rate of in situ soil (The soil application rate may be that which is listed for BOD₅ and TSS $>$ or \leq 30 mg/L depending on wastewater characteristics or fill depth below distribution cell. See Table 1.)

$$= \underline{450} \text{ gal/day} \div \underline{0.3} \text{ gal/ft}^2/\text{day}$$

$$= \underline{1500} \text{ ft}^2$$

b. Basal area available

1) Sloping site = Cell length (B) \times [(# of cells \times cell width) + ({# of cells - 1 } \times cell spacing) + down slope width] (A+I)

$$= 100 \text{ ft} \times [(\underline{1} \times \underline{4.5} \text{ ft}) + (\{ \underline{1} - \underline{1} \} \times \underline{0} \text{ ft}) + \underline{9.5} \text{ ft}]$$

$$= 100 \text{ ft} \times (\underline{4.5} \text{ ft} + \underline{0} \text{ ft} + \underline{9.5} \text{ ft})$$

$$= 100 \text{ ft} \times \underline{14} \text{ ft}$$

$$= \underline{1400} \text{ ft}^2$$

2) Level site = Cell length (B) \times total mound width (W)

$$= \underline{\quad} \text{ ft} \times \underline{\quad} \text{ ft}$$

$$= \underline{\quad} \text{ ft}^2$$

c. Is available basal area sufficient? ___ Yes X No

Basal area required $<$ Basal area available

$$\underline{1500} \text{ ft}^2 \leq \underline{1400} \text{ ft}^2$$

The available basal area must be increased by 100 ft^2 . This can be accomplished by increasing the down slope width (I) by 1 ft. making it 10.5 ft.

d. Basal area available (recalculation of basal area)

1) Sloping site = Cell length (B) x [(# of cells x cell width) + ({# of cells - 1 } x cell spacing) + down slope width] (A+I)

$$= 100 \text{ ft} \times [(1 \times 4.5 \text{ ft}) + (\{1 - 1\} \times 0 \text{ ft}) + 10.5 \text{ ft}]$$

$$= 100 \text{ ft} \times (4.5 \text{ ft} + 0 \text{ ft} + 10.5 \text{ ft})$$

$$= 100 \text{ ft} \times 15 \text{ ft}$$

$$= 1500 \text{ ft}^2$$

2) Level site = Cell length (B) x total mound width (W)

$$= \underline{\hspace{1cm}} \text{ ft} \times \underline{\hspace{1cm}} \text{ ft}$$

$$= \underline{\hspace{1.5cm}} \text{ ft}^2$$

5. Determine the location of observation pipes along the length of distribution cell.

Observation pipes will be installed in each distribution cell so as to be representative of a cell's hydraulic performance.

- be located such that there are a minimum of two installed in each dispersal cell at opposite ends from one another
- be located near the dispersal cell ends
- be at least 6 inches from the end wall and sidewall
- be installed at an elevation to view the horizontal or level infiltrative surface within the dispersal cell

Observation pipes may be located less than 6 inches from end walls or side walls if specified in state—approved manufacturers' installation instructions.

XII. PLAN SUBMITTAL AND INSTALLATION INSPECTION

A. Plan Submittal

In order to install a system correctly, it is important to develop plans that will be used to install the system correctly the first time. The following checklist may be used when preparing plans for review. The checklist is intended to be a **general guide**. Not all needed information may be included in this list. Some of the information may not be required to be submitted due to the design of the system. Conformance to the list is not a guarantee of plan approval. Additional information may be needed or requested to address unusual or unique characteristics of a particular project. Contact the reviewing agent for specific plan submittal requirements, which the agency may require that are different than the list included in this manual.

General Submittal Information

- Photocopies of soil report forms, plans, and other documents are acceptable. However, an original signature is required on certain documents.
- Submittal of additional information requested during plan review or questions concerning a specific plan must be referenced to the Plan Identification indicator assigned to that plan by the reviewing agency.
- Plans or documents must be permanent copies or originals.

Forms and Fees

- Application form for submittal, provided by reviewing agency along with proper fees set by reviewing agent.

Soils Information

- Complete Soils and Site Evaluation Report (form # SBD-8330) for each soil boring described; signed and dated by a certified soil tester, with license number.
- Separate sheet showing the location of all borings. The location of all borings and backhoe pits must be able to be identified on the plot plan.

Documentation

- Architects, engineers, or designers must sign, seal and date each page of the submittal or provide an index page, which is signed, sealed, and dated.
- Master Plumbers must sign, date, and include their license number on each page of the submittal or provide an index page, which is signed, sealed, and dated.
- A detailed project description must be submitted with all commercial plans. Any facility creating non-domestic wastewater may require concurrence approval from the WI. DNR. Please check with a state plan reviewer if there are any questions).
- Submittals if on paper must measure at least 8-1/2 by 11 inches.
- Designs that are based on department approved component manual(s) must include reference to the manual by name, publication number and published date.

Plot Plan

- Dimensioned plans or plans drawn to scale (scale indicated on plans) with parcel size or all property boundaries clearly marked.
- Slope directions and percent in system area.
- Bench mark and north arrow.
- Setbacks indicated as per appropriate code.
- Two-foot contours or other appropriate contour interval within the system area.
- Location information; legal description of parcel must be noted.
- Location of any nearby existing system or well.

Plan View

- Dimensions for distribution cell(s).
- Location of observation pipes.
- Dimensions of mound.
- Pipe lateral layout, which must include the number of laterals, pipe material, diameter and length; and number, location and size of orifices.
- Manifold and force main locations, with materials, length, and diameter of each.

Cross Section of System

- Include tilling requirement, distribution cell details, percent slope, side slope, and cover material.
- Lateral elevation, position of observation pipes, dimensions of distribution cell, and type of cover material such as geotextile fabric, if applicable.

System Sizing

- For one and two-family dwellings, the number of bedrooms must be included.
- For public buildings, the sizing calculations must be included.

Tank And Pump or Siphon Information

- All construction details for site-constructed tanks.
- Size and manufacturer information for prefabricated tanks.
- Notation of pump or siphon model, pump performance curve, friction loss for force main and calculation for total dynamic head.
- Notation of high water alarm manufacturer and model number.
- Cross section of dose tank / chamber to include storage volumes; connections for piping, vents, and power; pump “off” setting; dosing cycle and volume, high water alarm setting, and storage volume above the highwater alarm; and location of vent and manhole.
- Cross section of two compartments tanks or tanks installed in a series must include information listed above.

B. Inspections

Inspection shall be made in accordance with ch. 145.20, Wis. Stats. and s. SPS 383.26, Wis. Adm. Code. The inspection form on the following two pages may be used. The inspection of the system installation and/or plans is to verify that the system at least conforms to specifications listed in Tables 1 - 3 of this manual.

Do your Part— Be SepticSmart!

A Homeowners' Guide to Septic Systems




septicSMART

U.S. Environmental Protection Agency

Maintaining Your Septic System:

Good for your wallet. Good for your health. Good for the environment.

Did you know that one-quarter of all U.S. homes have septic systems? Yours may be one of them. If you're not properly maintaining your septic system, you're not only hurting the environment, you're putting your family's health at risk—and may be flushing thousands of dollars down the drain!

First Things First:

What Is a Septic System?

Common in rural areas without centralized sewer systems, septic systems are underground wastewater treatment structures that use a combination of nature and time-tested technology to treat wastewater from household plumbing produced by bathrooms, kitchen drains, and laundry.

Do You Have a Septic System?

You may already know you have a septic system. If you don't know, here are tell-tale signs that you probably do:

- You use well water.
- The waterline coming into your home doesn't have a meter.
- You show a "\$0.00 Sewer Amount Charged" on your water bill.
- Your neighbors have a septic system.



How To Find Your Septic System

Once you've determined that you have a septic system, you can find it by:

- Looking on your home's "as built" drawing.
- Checking your yard for lids and manhole covers.
- Contacting a septic inspector/pumper to help you locate it.

Why Should You Maintain Your Septic System?

Maintaining Your Septic System...

Saves You Money

Regular maintenance fees of \$250 to \$300 every three to four years is a bargain compared to the cost of repairing or replacing a malfunctioning system, which can cost between \$3,000 and \$7,000. The frequency of pumping required for your system depends on how many people live in your home and the size of the system.

Protects Your Property Value

An unusable septic system or one in disrepair will lower your property value, not to mention pose a potentially costly legal liability.

Keeps You and Your Neighbors Healthy

Household wastewater is loaded with disease-causing bacteria and viruses, as well as high levels of nitrogen and phosphorus. If a septic system is well-maintained and working properly, it will remove most of these pollutants. Insufficiently treated sewage from septic systems can cause groundwater contamination, which can spread disease in humans and animals.

Improperly treated sewage also poses the risk of contaminating nearby surface waters, significantly increasing the chance of swimmers contracting a variety of infectious diseases, from eye and ear infections to acute gastrointestinal illness and hepatitis.

Service provider coming? Here's what you need to know.

When you call a septic service provider, he or she will inspect for leaks and examine the scum and sludge layers in your septic tank.

Your septic tank includes a T-shaped outlet which prevents sludge and scum from leaving the tank and traveling to the drainfield area. If the bottom of the scum layer is within six inches of the bottom of the outlet, or if the top of the sludge layer is within 12 inches of the outlet, your tank will need to be pumped. Remember to note the sludge and scum levels determined by the septic professional in your operation and maintenance records, as this will help determine how often pumping is necessary.

The service provider should note any repairs completed and the tank condition in your system's service report. If additional repairs are recommended, be sure to hire someone to make them as soon as possible.

The National Onsite Wastewater Recycling Association (NOWRA) website has a septic locator that makes it easy to service professionals in your area. Visit www.septiclocator.com and enter your ZIP code to get started!

Beware of septic tank additives!

Some makers of septic tank additives claim their products break down septic tank sludge in order to eliminate the need for pumping. But the effectiveness of additives has not been determined; in fact, many studies show that additives have no significant effects on a tank's bacterial populations.

Septic tanks already contain the microbes they need for the effective breakdown of household wastewater pollutants. Periodic pumping is the only true way to ensure that septic systems work properly and provide many years of service.

Protects the Environment

More than four billion gallons of wastewater is dispersed below the ground's surface every day. That's a lot of water! Groundwater contaminated by poorly or untreated household wastewater doesn't just pose dangers to drinking water—it poses dangers to the environment. Malfunctioning septic systems release bacteria, viruses, and chemicals toxic to local waterways. When these pollutants are released into the ground, they eventually enter streams, rivers, lakes, and more, harming local ecosystems by killing native plants, fish, and shellfish.

Maintaining Your Septic System:

The Basics

Septic system maintenance isn't complicated, and it doesn't need to be expensive. Upkeep comes down to four important elements:

- Inspection and pumping
- Water efficiency
- Proper waste disposal
- Drainfield care

Inspect and pump frequently

The average household septic system should be inspected at least every three years by a septic service professional. Household septic tanks are typically pumped every three to five years. Alternative systems with electrical float switches, pumps, or mechanical components need to be inspected more often, generally once a year. A service contract is important since alternative systems have mechanized parts.

Four major factors influence the frequency of septic pumping:

- Household size
- Total wastewater generated
- Volume of solids in wastewater
- Septic tank size



Use water efficiently

Did you know that average indoor water use in a typical single-family home is nearly 70 gallons per individual, per day? And just a single leaky toilet can waste as much as 200 gallons of water per day?

All of the water a household sends down its pipes winds up in its septic system. This means that the more water a household conserves, the less water enters the septic system. Efficient water use can not only improve the operation of a septic system, but it can reduce the risk of failure as well. Learn more about simple ways to save water and water-efficient products by visiting EPA's WaterSense Program at www.epa.gov/watersense.

- **High-efficiency toilets:** Toilet use accounts for 25 to 30 percent of household water use. Most older homes have toilets with 3.5- to 5-gallon reservoirs, while newer, high-efficiency toilets use 1.6 gallons of water or less per flush. Replacing existing toilets with high-efficiency models is an easy way to quickly reduce the amount of household water entering your septic system.
- **Faucet aerators and high-efficiency showerheads:** Faucet aerators help reduce water use as well as the volume of water entering your septic system. High-efficiency showerheads or shower flow restrictors also reduce water use.
- **Washing machines:** Washing small loads of laundry on your washing machine's large-load cycle wastes water and energy. By selecting the proper load size, you'll reduce water waste. If you're unable to select a load size, run only full loads of laundry.

Another tip? Try to spread water use via washing machine throughout the week. Doing all household laundry in one day might seem like a time-saver, but it can be harmful to your septic system, as it doesn't allow your septic tank time to adequately treat waste and could potentially flood your drainfield.

Consider purchasing an ENERGY STAR® clothes washer, which uses 35 percent less energy and a whopping 50 percent less water than a standard model. Learn more about ENERGY STAR appliances by visiting www.energystar.gov.

Small leaks can lead to big problems!

When it comes to water fixtures, a couple of quick fixes can save you serious problems down the road!

Check to see if your toilet's reservoir is leaking into your toilet bowl by adding five drops of liquid food coloring to the toilet reservoir before bed. If the dye is in the toilet bowl the next morning, the reservoir is leaking and repairs are needed.

Think a leaky faucet is no big deal? Think again. A small drip from a faucet adds gallons of unnecessary water to your septic system every day.

To see how much a leak adds to your water usage, place a cup under the drip for 10 minutes. Multiply the amount of water in the cup by 144 (the number of minutes in 24 hours, divided by 10). Just one cup of leaky faucet water every 10 minutes equals 36 wasted gallons of water a day—and they all end up in your septic system.

New faucets and toilet reservoirs are easily accessible and inexpensive. Choose to make a small investment for a big difference in your septic system.

- **Proper waste disposal:** Whether you flush it down the toilet, grind it in the garbage disposal, or pour it down the sink, shower, or bath, everything that goes down your drains ends up in your septic system. And what goes down the drain can have a major impact on how well your septic system works.

Toilets Aren't Trash Cans!

Your septic system is not a trash can. An easy rule of thumb? Don't flush anything besides human waste and toilet paper.

Never flush:


- Feminine hygiene products
- Condoms
- Dental floss
- Diapers
- Cigarette butts
- Coffee grounds
- Cat litter
- Household chemicals like gasoline, oil, pesticides, antifreeze, and paint
- Pharmaceuticals

For a complete list, visit water.epa.gov/septicsmart.

How does a septic system work?

This is a simplified overview of how a septic system works.

- 1 All water runs out of your house from one main **drainage pipe** into a septic tank.
- 2 The **septic tank** is a buried, water-tight container usually made of concrete, fiberglass or polyethylene. Its job is to hold the wastewater long enough to allow solids to settle down to the bottom (forming sludge), while the oil and grease floats to the top (as scum). Compartments and a T-shaped outlet prevent the sludge and scum from leaving the tank and traveling into the drainfield area.
- 3 The liquid wastewater then exits the tank into the **drainfield**. If the drainfield is overloaded with too much liquid, it will flood, causing sewage to flow to the ground surface or create backups in toilets and sinks.
- 4 Finally, the wastewater percolates into the **soil**, naturally removing harmful bacteria, viruses, and nutrients.



Own an RV, boat or mobile home?

If you spend any time in a recreational vehicle (RV) or boat, you probably know of the problem of odors from sewage holding tanks. Learn more about proper and safe wastewater disposal—download EPA's factsheet at www.epa.gov/region9/water/groundwater/uic-pdfs/rv-wastewater.pdf or call The National Small Flows Clearinghouse's Septic System Care hotline toll-free at 1-800-624-8301.

Take care at the drain


Your septic system contains a collection of living organisms that digest and treat household waste. Pouring toxins down your drain can kill these organisms and harm your septic system. Whether you're at the kitchen sink, bathtub, or utility sink:

- Avoid chemical drain openers for a clogged drain. Instead, use boiling water or a drain snake.
- Never pour cooking oil or grease down the drain!
- Never pour oil-based paints, solvents, or large volumes of toxic cleaners down the drain. Even latex paint waste should be minimized.
- Eliminate or limit the use of a garbage disposal, which will significantly reduce the amount of fats, grease, and solids that enter your septic tank and ultimately clog its drainfield.

Maintain your drainfield

Your drainfield—a component of your septic system that removes contaminants from the liquid that emerges from your septic tank—is an important part of your septic system. Here are a few things you should do to maintain it:

- Never park or drive on your drainfield.
- Plant trees the appropriate distance from your drainfield to keep roots from growing into your septic system. A septic service professional can advise you of the proper distance, depending on your septic tank and landscape.
- Keep roof drains, sump pumps, and other rainwater drainage systems away from your drainfield area, as excess water slows down or stops the wastewater treatment process.



Failure Causes

Pouring household and home improvement chemicals down your drains, flushing garbage down toilets, excessive water use, and failure to provide proper maintenance aren't the only culprits for septic system failure. Take note of these additional causes of septic failure:

Hot tubs

Hot tubs may be a great way to relax, but when it comes to emptying them, your septic system should be avoided. Emptying a hot tub into your septic system stirs the solids in the tank, pushing them into the drainfield, causing it to clog and fail.

Drain cooled hot tub water onto turf or landscaped areas far away from your septic tank and drainfield, and in accordance with local regulations. Use the same caution when draining swimming pools.

Water purification and softening systems

Some freshwater purification systems, including water softeners, unnecessarily pump water into septic systems. Such systems can send hundreds of gallons of water to septic tanks, causing agitation of solids and excess flow to drainfields. When researching water purification and softening systems, check with a licensed plumbing professional about alternative routing for such treatment systems.

Garbage disposals

Consider eliminating or limit the use of garbage disposals. While convenient, frequent use of garbage disposals significantly increases the accumulation of sludge and scum in septic tanks, resulting in the need for more frequent pumping.

Improper design or installation

The proper design and installation of a septic system is essential for it to correctly function. A home's groundwater table, soil composition, and a properly leveled drainfield are just a few factors to ensure a well-functioning septic system. Be sure to do your research when hiring septic professionals.



Failure symptoms: Mind the signs!

A foul odor isn't always the first sign of a malfunctioning septic system. Call a septic professional if you notice any of the following:

- Wastewater backing up into household drains.
- Bright green, spongy grass on the drainfield, even during dry weather.
- Pooling water or muddy soil around your septic system or in your basement.
- A strong odor around the septic tank and drainfield.

Mind the signs of a failing system. One call to a septic professional could save you thousands of dollars!



U.S. Environmental Protection Agency

For more information on how you can
be SepticSmart, please visit:

www.epa.gov/septicmart

EPA-832-B-12-005
September 2012